

certificate
no. **IFA 2504127**
dated 2025-07-01



IFA

Institut für Arbeitsschutz der
Deutschen Gesetzlichen Unfallversicherung
Prüf- und Zertifizierungsstelle im DGUV Test

Translation In any case, the German original shall prevail.

DGUV Test Certificate

Name and address of the
holder of the certificate
(customer): STACO Holding B.V.,
Molenweg 1
5953 Reuver
NETHERLANDS

Product designation: **Perforated metal planks, hot-dip galvanized**

Type: Steel perfo plank – AP ...x30/OFF

Testing based on: DIN EN 16165:2023-02 annex B; Determination of slip
resistance of pedestrian surfaces - Shod ramp test

ASR A1.5; Technical rules for workplaces – floorings;
Edition: March 2022

DIN 51130:2023-02 - Testing of floor coverings -
Determination of the displacement space


Test report: No. 2025 21650/3210 dated 2025-07-01
- IFA, Sankt Augustin

Further details: Intended purpose:
Floor covering for use in working areas presenting a risk
of slipping, for which floor coverings of slip resistance
assessment group R11/V10 are specified.

Remarks:
The DGUV test mark may be used only in conjunction with indication
of the slip resistance assessment group and the displacement space.

The type tested complies with the test basis specified above. The holder of the certificate is
entitled to affix the DGUV Test mark shown overleaf to the products complying with the type
tested, including the specification given under the heading further details.
The present certificate including the right to affix the DGUV Test mark is valid until: **2030-06-09**

Further provisions concerning the validity, the extension of the validity and other conditions
are laid down in the Rules of Procedure for Testing and Certification.



Dr. rer. nat. Peter Paszkiewicz
Head of Certification Body



Dipl.-Ing. Olaf Mewes
Certification Officer

DGUV Test mark

